

62-021 Sarbinowo ul. Długa 12 tel.+48 61 897 36 03/04/32 e-mail: biuro@norson.pl norson@norson.pl

DECLARATION OF PERFORMANCE No. 25/16

- 1. The name and trade name of the construction product: Flanged service cleaner (TKH) with a PN10/16 hydrant valve
- 2. Type designation of a construction product:

 Revision cleaner with hydrant 52mm valve; catalog number 1-136
- Intended use or uses of a construction product: designed for cleaning pipelines and performing other revision operations in water supply installations, sewage installations, industrial water and other chemical inert fluids (NBR), for water drinking water (EPDM).
- 4. Name and address of the manufacturer's premises and place of production of the product:

Norson Sp. z o.o. Sp. K. Sarbinowo, ul. Długa 12 62-021 Paczkowo

- 5. Where appropriate, the name and contact address of the authorized representative whose mandate covers the tasks specified in art. 12 p. 2: **not applicable.**
- 6. System or systems for assessment and verification of constancy of performance of a construction product as defined in the Annex to the Regulation: system 4.
- 7. National technical specification:
- 7a. Polish Product standard: **PN-EN 1074-1: 2002**The name of the accredited certification body, accreditation number and national certificate Number or the name of the accredited laboratory: **not applicable.**
- 7b. National technical evaluation: -

8. Declared performance.

Essential characteristics	Useful properties	Technical Specifications
- maximum working pressure	1,0MPa or 1,6MPa	
- flange drilling	PN10 or PN16	PN-EN 1092-2:1999
- nominal diameter range	DN50-DN300	
- external and internal protective cover	epoxy paint with a thickness of min. 250µm	manufacturer's specification
- material	EN-GJS-500-7	PN-EN 1563:2012
	EN-GJL-250	PN-EN 1561:2012

9. The performance of the product specified above is in accordance with all declared performance in point 8. This national declaration of performance is issued in accordance with the Act of 16 April 2004 on construction products, under the sole responsibility of the manufacturer.

On behalf of the manufacturer

PEŁNOMOCNIK Systemu Zafzadzania Jakością mgr inż. Robert Mglej

Sarbinowo, September 1, 2017 (place and date of issue)